

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3230-0368:113 Page 1 of 1

**CATEGORY:** Leakage Dampers

**LISTEE:** Pottorff, \*2824 N. Sylvania Ave., Fort Worth, TX 76111  
Contact: Michael Beaver (817) 831-7038

**DESIGN:** Models SD-25R and FSD-125R round single leakage damper. Unit constructed of No. 20 Ga. galvanized steel sleeve and frame and double membrane No. 14 Ga. or equivalent galvanized steel blade. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** FSD-125R: Class I-350  
SD-25R: Class II-350  
  
FSD-125R: minimum 8" and maximum 18" in diameter  
SD-25R: minimum 6" and maximum 18" in diameter

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, leakage rating and UL label.

**APPROVAL:** Listed as leakage rated dampers for use in heating, ventilating and air conditioning duct systems passing through fire resistive walls and partitions. Suitable for vertical and horizontal mount.

\*Rev 06-15-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager